



DRAFT Galveston Island Revised Pump Station Sizes

Coastal Texas Restoration and Protection
Feasibility Study



Presentation Summary

- Mott MacDonald tasked to investigate changes in required pump size at Galveston Island due to revised extremal conditions developed by the USACE.
 - Task A.1 of Amendment 6.
 - Old Extremal conditions yielded almost no overtopping of Levee
- Revised 100 year, 90% CI WSE with 0.0' used to calculate overtopping per USACE direction.
 - Resulting overtopping rates were calculated along the revised alignment
- Timesteps for overtopping were modified to align with peak rainfall runoff inflow at each pump site.
- **This presentation investigates required changes to the proposed pump station sizes and conveyance channel cross sections due to including the overtopping along the revised alignment.**

Previous vs. Revised Alignment


Map



- Overtopping rates (cfs/lf) were calculated along 7 different segments of the new Alignment

Overtopping Analysis Summary

- Timeseries of wave and WSE (scaled) used to calculate overtopping rates at each extraction point.
- Example timeseries shown on right.
- **0.0' SLR Results used.**
- **No seawall overtopping included.**
- Peak overtopping rate and associated peak volumetric flow rate shown in tables on right.
 - **Red numbers** above ultimate overtopping limit (1 cfs/ft)
 - **Orange numbers** above no-damage limits (90%: 0.1 cfs/ft, 50%: 0.01 cfs/ft).




Rate [cfs/ft]

Point	50% CI 0.0' SLR	90% CI 0.0' SLR
11892	0.03	0.61
17284	0.30	1.76
12962	0.07	1.06
12773	0.003	0.19
12841	0.002	0.01
17276	0.05	0.39

Volume [cfs]

Point	50%CI 0.0' SLR	90%CI 0.0' SLR
11892	380	7,553
17284	2,594	15,376
12962	726	11,014
12773	28	2,004
12841	21	89
17276	772	6,212


Note: Results with 0.0 ft SLR.



Galveston: Pump Station 1 Location & Stormwater Conduit

- Preliminary Pump Size¹: 250 cfs
- Preliminary Drainage Conduit¹:
 - Length: 9,549 LF
 - Dimensions: 30'W x 13'H


Note¹: Current pump design does not include overtopping of seawall. Overtopping volume will be incorporated into pump sizes once further analysis is conducted.



Galveston: Pump Station 2 Location & Stormwater Conduit

- Preliminary Pump Size¹: 1,500 cfs
- Preliminary Drainage Conduit¹:
 - Length: 5,670 LF
 - Dimensions: 20'W x 10'H

Note¹: Current pump design does not include overtopping of seawall. Overtopping volume will be incorporated into pump sizes once further analysis is conducted.



Galveston: Pump Station 3 Location & Stormwater Conduit



- Preliminary Pump Size¹: 4,500 cfs
- Preliminary Drainage Conduits¹:
 - Length: 9,075 LF
 - Dimensions: 20'W x 10'H

Note¹: Current pump design does not include overtopping of seawall. Overtopping volume will be incorporated into pump sizes once further analysis is conducted.




Galveston: Pump Station 4 Location & Stormwater Conduit



- Preliminary Pump Size¹: 1,500 cfs
- Preliminary Drainage Conduits¹:
 - Length: 12,075 LF
 - Dimensions: 20'W x 10'H

Note¹: Current pump design does not include overtopping of seawall. Overtopping volume will be incorporated into pump sizes once further analysis is conducted.

Review of Previous SWMM Model Grid



- Note: model layout only serves as visual representation of the system; does not show actual physical locations of proposed pumps and channels

Review of Previous Required Pump and Channel Sizes & Design Conditions

- Design conditions:

- *Rain & Overtopping:*

- 25-yr + 30% rainfall (24 hr event)
 - No overtopping

- *Operational Procedure & Constraints:*

- Offatts Bayou gate closed
 - Offatts Bayou de-watered to elevation of 1 ft below MLW
 - Max allowable surface elevation within Offatts Bayou of +4.0 ft NAVD88
 - No allowable surface flooding



Parameter	Design Conditions for 25-yr+30% Rainfall (no overtopping)	
	Total Peak Inflow into Pump Site (cfs)	Required Pump and Channel Sizes
Offatts Pump Size	22,830	250 cfs
Broadway Ave. Conveyance channel		30' wide x 13' high 390 sf
Pump Site 2 - Pump	1,765	1,500 cfs
Pump Site 2 - Conveyance channel		20' wide X 10' high 200 sf
Pump Site 3 - Pump	3,688	4,500 cfs
Pump Site 3 - Conveyance Channel		20' wide X 10' high 200 sf
Pump Site 4 - Pump	2,208	1,500 cfs
Pump Site 4 - Conveyance Channel		20' wide X 10' high 200 sf


Applying Revised Alignment Overtopping Rates to Existing Model

- Sub-basins drain to color-coded pump stations via conveyance channels (not shown)
 - Ex: PS 1, PS 2, etc.
- Overtopping rates were applied to the pump station systems using the rate (cfs/lf) multiplied by the length (lf) of the revised alignment that is adjacent to each existing sub-basin.
 - Results in a volumetric rate (cfs) of overtopping that gets directed into the correlated pump site system
- No overtopping was recorded along the northeastern edge of the alignment




Resulting Inflow per Pump Site

Inflow Into Each Pump Site Due to 100-yr Overtopping Along Revised Alignment vs. 25-yr+30% Rainfall Runoff




Model Results

Original vs. Revised Pump Sizes



Original Pump Design (cfs)	250	1500	4500	1500
Revised Pump Design (cfs)	4500	1500	5000	5000

Original vs. Revised Channel Sizes



Original Cross Section Area (sf)	390	200	200	200
Revised Cross Section Area (sf)	416	200	300	250

- **Pump Size Change Summary:**
 - **Largest increases at Pump Site 1,4.** This is due to overtopping being relatively high at these sites compared to the other two,
 - Small increases at Pump Site 3.
- **Channel Size Change Summary:**
 - Pump sizes were iterated to maintain depth, but increase width as necessary to efficiently route the water to the pump stations.

Results Summary

- Pump Site 1 (Offatts Bayou)
 - Increase in pump size
 - Increase in channel cross section
 - Increase in Offatts Bayou max water elevation
- Pump Site 2
 - No increase
- Pump Site 3
 - Increase in pump size
 - Increase in channel cross section
- Pump Site 4
 - Increase in pump size
- No changes were made to conveyance channel locations, lengths, depths, slopes, or elevations

Parameter	Updated Conditions for 25-yr+30% Rainfall + 100-yr Overtopping Along Revised Alignment		
	Total Peak Inflow into Pump Site (cfs)	% Increase of Peak Inflow due to Overtopping	Required Pump Sizes
Offatts Pump Size	57,499	152%	4,500 cfs
Broadway Ave. Conveyance channel			32' wide x 13' high 416 sf
Pump Site 2 - Pump	1,984	12%	1,500 cfs
Pump Site 2 - Conveyance channel			20' wide X 10' high 200 sf
Pump Site 3 - Pump	5,507	49%	5,000 cfs
Pump Site 3 - Conveyance Channel			30' wide x 10' high 300 sf
Pump Site 4 - Pump	5,885	167%	5,000 cfs
Pump Site 4 - Conveyance Channel			25' wide x 10' high 250 sf

Conclusions

- At currently proposed +14.0' floodwall elevation along the backside of Galveston, significant overtopping is expected.
- Additional overtopping results in an increase of required pump sizes, with the largest pump now being 5,000 cfs.
- **Would like USACE concurrence on drainage modeling methodology & pump sizes before moving forward with cost estimating effort.**



Thank you

